

TEMPERATURY CZYNNIKA GRZEWczego STREFA - 18°C**Miasto JANIKOWO**

Temperatura Zewnętrzna	Sieć ciepła 130/90		Instalacje wewnętrzne			
	Z	P	95/70		90/70	
			Z	P	Z	P
1	2	3	4	5	6	7
- 18	130,0	80,0	95,0	70,0	90,0	70,0
- 17	125,0	79,0	93,5	69,0	89,0	69,5
- 16	125,0	78,0	92,0	68,0	87,5	68,5
- 15	120,0	77,0	90,0	67,0	86,5	67,5
- 14	120,0	75,5	89,0	66,0	85,0	67,0
- 13	115,0	74,5	87,0	65,5	84,0	66,0
- 12	115,0	73,5	85,0	64,5	82,0	65,0
- 11	115,0	72,5	83,5	63,0	81,0	64,0
- 10	110,0	71,0	82,0	62,0	79,5	63,0
- 9	105,0	70,0	80,0	61,5	78,0	62,0
- 8	105,0	69,0	78,5	60,5	76,5	61,0
- 7	100,0	67,5	77,0	59,5	75,5	59,5
- 6	100,0	66,5	75,5	58,5	74,0	58,5
- 5	95,0	65,0	73,5	57,0	72,5	57,5
- 4	95,0	63,5	72,0	56,0	71,0	56,5
- 3	90,0	62,5	70,0	55,0	69,5	55,5
- 2	90,0	61,0	68,5	54,0	67,5	54,0
- 1	85,0	60,0	66,5	52,5	66,5	53,0
0	85,0	58,5	65,0	52,0	65,0	52,0
+ 1	80,0	57,0	63,0	50,5	63,5	51,0
+ 2	80,0	55,5	61,5	49,5	62,0	50,0
+ 3	80,0	54,0	59,5	48,5	60,0	48,5
+ 4	75,0	53,0	58,0	47,5	58,5	47,0
+ 5	75,0	51,5	56,0	46,0	56,5	46,0
+ 6	70,0	49,5	54,0	45,0	54,5	45,0
+ 7	70,0	48,5	52,0	43,5	53,0	44,0
+ 8	70,0	46,5	50,5	42,0	51,0	42,0
+ 9	70,0	45,0	48,5	41,0	49,0	41,0
+ 10	65,0	43,0	46,0	39,5	47,0	39,5
+ 11	65,0	42,0	44,0	38,0	45,0	38,0
+ 12	65,0	40,0	42,5	36,5	43,0	36,5